

Approval Number: 1811518  
Test Report: MA6217/F



Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

18<sup>th</sup> October 2018

Weicon GmbH & Co. KG  
Koenigsberger Strasse 255,  
48157 Muenster,  
Germany

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)  
CONSECUTIVE MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**SEALANTS - SCREWED JOINTS - ANAEROBIC ADHESIVES. THESE PRODUCTS ARE TO BE APPLIED AND CURED IN STRICT ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS** **5520**

'WEICONLOCK AN 305-77'. Yellow coloured anaerobic adhesive paste. This product is to be applied and cured in strict accordance with the manufacturer's instructions. For use with water up to 85°C.

**APPROVAL NUMBER: 1811518**  
**APPROVAL HOLDER: WEICON GMBH & CO. KG**

This is a re-approval of 1310559 which is valid between October 2013 and October 2018.

The Scheme reserves the right to review approval.  
Approval 1811518 is valid between November 2018 and November 2023

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme