

Approval Number: 2006504
Test Report: MA6880/1



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

4th May 2020

Weicon GmbH & Co. KG
Koenigsberger Strasse 255,
48157 Muenster,
Germany

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
CONSECUTIVE MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

SEALANTS - SCREWED JOINTS - ANAEROBIC ADHESIVES. THESE PRODUCTS ARE TO BE APPLIED AND CURED IN STRICT ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS **5520**

'WEICONLOCK AN 306-20'. Green coloured anaerobic adhesive. For use with water up to 85°C.

This product is to be applied and cured in strict accordance with the manufacturer's instructions

APPROVAL NUMBER: 2006504
APPROVAL HOLDER: WEICON GMBH & CO. KG

This is a re-approval of 1505543 which is valid between May 2015 and May 2020.

The Scheme reserves the right to review approval.
Approval 2006504 is valid between June 2020 and June 2025

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme